
SOURCE WATER ASSESSMENT

for

Lake Linganore Water Treatment Plant Frederick County



Prepared by
Maryland Department of the Environment
Water Management Administration
Water Supply Program
April 2005



Robert L. Ehrlich, Jr. *Governor*

Michael S. Steele Lt. Governor

Kendl P. Philbrick Secretary

Jonas A. Jacobson Deputy Secretary

TABLE OF CONTENTS

	EXECUTIVE SUMMARY	iii
1.0	BACKGROUND	1
2.0	INTRODUCTION	1
	A. Description of Surface Water Supply Source	2
	B. Water Suply Development	
3.0	RESULTS OF SITE VISIT(S)	3
	Concerns and Site Observations	3
4.0	WATERSHED CHARACTERIZATION	4
	Source Water Assessment Area Delineation Method (Surface Water)	.4
	General Characteristics	4
	Land Use Characteristics	4
	Table 1. 2000 Land Use Data	4
	Localized Characteristics	5
5.0	SIGNIFICANT SOURCES OF CONTAMINATION	5
	Non-Point Concerns	
	Point Source Concerns	6
	Transportation Related Concerns	
	Land Use Planning Concerns	
	Table 2. Land Use Planning Concerns	
6.0	REVIEW OF WATER QUALITY DATA	7
	Existing Plant Data	
	Raw Water Turbidity and pH	
	Table 3. Linganore Plant Raw Water Turbidity and pH for 2000	
	Inorganic Compounds (IOCs)	
	Table 4. Inorganic Compounds (IOCs) from Lake Linganore	
	Radionuclides	
	Synthetic Organic Compounds (SOCs)	11
	Table 5. Synthetic Organic Compounds (SOCs) Lake Linganore	
	Creek Source	
	Volatile Organic Compounds (VOCs)/Disinfection Byproduct	
	Table 6. Annual Concentrations of Disinfection Byproducts	
	In Lake Linganore Distribution System (all sample locations)	13

	Table 7. Quarterly Average Concentrations of Disinfection	
	Byproducts in the Distribution System	13
	Table 8. Quarterly Average Concentrations of Source and	
	Treated Total Organic Carbon and Percent Removed (2001 thr	ough
	2004) at the Lake Linganore Water Treatment Plant	
	Table 9. MCLs for the Stage 1 DBPR	
	Table 10. Total Organic Carbon Removal Requirements	
	Protozoa and Fecal Coliform	
	Table 11. Monthly Summary of Lake Linganore Intake Result	
	for Fecal Coliform	
	Table 12. Storm Event #1 Cryptosporidium Results	
	Table 13. Storm Event #2 Cryptosporidium Results	
	Table 14. Storm Event #3 Cryptosporidium Results	17
	Table 15. Storm Event #4 Cryptosporidium Results	
7.0	SUSCEPTIBILITY ANALYSIS	17
	Turbidity and Sediment	17
	Inorganic Compounds	18
	Total Phosphorus	18
	Synthetic Organic Compounds (SOCs)	19
	Disinfection Byproducts	19
	Microbiological Contaminants	20
8.0	RECOMMENDATIONS FOR SOURCE WATER	
	PROTECTION PLAN	20
REI	FERENCES	22
OTI	HER SOURCES OF DATA	23
FIG	URES	24
A TOT	DENDIY	25
~ ~ ~	PH NIDE T	, ,

EXECUTIVE SUMMARY

The 1996 Safe Drinking Water Act Amendments require states to develop and implement source water assessment programs to evaluate the safety of all public drinking water systems. A Source Water Assessment (SWA) is a process of evaluating the vulnerability of a source of public drinking water supply to contamination. This SWA was completed for Lake Linganore, the source of water supply for Frederick County's Lake Linganore Water Treatment Plant.

Lake Linganore is the largest impoundment in Frederick County and is located east of the City of Frederick, Maryland. The lake is owned by the Lake Linganore Association and lies on Linganore Creek, a tributary of Monocacy River. An earthen dam was installed in 1972 to create the lake for the purpose of water supply and for recreational use. Raw water flows by gravity through an 18-inch line by using control valves to withdraw water from different lake levels to the water treatment plant.

The source water protection area for Lake Linganore intake encompasses approximately 81 square miles of mixed land use with predominantly cropland and forested land. The entire watershed is located in Frederick County with a small portion extending into Carroll County.

Potential sources of contamination for Lake Linganore Watershed include point and non point sources, including transportation, agriculture, on-site septic systems and runoff from developed areas. The only point source is the Libertytown Wastewater Treatment Plant. The County is in the process of replacing this wastewater treatment plant with a new pump station. The wastewater from the community of Libertytown will be pumped to the nearby sewer and treated in Frederick County's Wastewater Treatment Plant outside of the watershed.

Frederick County maintains a water quality monitoring program for the water treatment plant by routine water sampling after filtration and raw water monitoring from Lake Linganore.

The susceptibility analysis indicates that phosphorus, turbidity, disinfection byproduct precursors and pathogenic protozoans are the most significant contaminants of concern.

Section 8.0 of this report lists specific recommendations for consideration in developing a source water protection plan. Providing critical information for implementing a source water protection program for Lake Linganore is the ultimate goal of this assessment

1.0 BACKGROUND

The 1996 Safe Drinking Water Act Amendments require states to develop and implement source water assessment programs to evaluate the potential for contaminants to affect the sources of all public drinking water systems. A Source Water Assessment (SWA) follows a process for evaluating the susceptibility of a public drinking water supply to contamination. The assessment does not address the treatment processes or the storage and distribution of the water system, which are covered under separate provisions of the Safe Drinking Water Act. The Maryland Department of the Environment (MDE) is the lead state agency in this SWA effort.

There are three main steps in the assessment process: (1) delineating the watershed drainage area that is likely to contribute to the drinking water supply, (2) identifying potential contaminants within that area and (3) assessing the vulnerability of the system to those contaminants. This document reflects all of the information gathered and analyzed required by those three steps. MDE looked at many factors to determine the susceptibility of this water supply to contamination, including the size and type of water system, available water quality data, the characteristics of the potential contaminants, and the capacity of the natural environment to attenuate any risk.

Maryland has more than 3,800 public drinking water systems. Approximately 50 of Maryland's public drinking water systems obtain their water from surface supplies, either from a reservoir or directly from a river. The remaining systems use ground water sources. Maryland's Source Water Assessment Plan was submitted to the Environmental Protection Agency (EPA) in February 1999, and received final acceptance by the EPA in November 1999. A copy of the plan can be obtained at MDE's website, www.mde.state.md.us, or by calling the Water Supply Program at 410-537-3714.

2.0 INTRODUCTION

The Lake Linganore water system is owned and operated by Frederick County Department of Public Works and serves Lake Linganore and Spring Ridge Planned Unit Developments (PUDs) with an estimated population of 13,200 people. The Lake Linganore water system's service area is generally located in the central part of Frederick County and is part of New Market Region Comprehensive Plan. Currently, the raw water is supplied by surface water from Lake Linganore, constructed in 1972 as a 833,000,000 gallon reservoir, formed by flooding Linganore Creek. The County withdraws water directly from Lake Linganore and the City of Frederick intake is located on Linganore Creek approximately 1 ½ miles downstream of the dam.

Almost 75% of the County's water system customers receive treated water from surface water supplies, specifically the Potomac River and Lake Linganore. The remaining 25% of the customers receive water from wells (Frederick County Bureau of Water and Sewer, Annual Water-Quality Report). The Potomac River Source Water Assessment for Frederick County's New Design Road water treatment plant is completed under a separate report.

A. Description of Surface Water Supply Source

Lake Linganore is an impoundment located near the City of Frederick in Frederick County, Maryland (Figure 1). The impoundment, which is owned by the Lake Linganore Association, lies on Linganore Creek, a tributary of Monocacy River. An earthen dam was installed in 1972 to create the lake for the purpose of water supply and for recreational use. According to the Phase I Dam Inspection Report which was prepared for the U.S. Army Corps of Engineers (1980), the lake covered 215 acres at the normal pool elevation of 308 feet above mean sea level with volume of 2,700 acre feet. The lake is approximately 3.7 miles long with maximum depth of 40 feet and average depth of 12 feet and it is the largest impoundment in Frederick County.

The watershed above the intake is approximately 81 square miles of mixed land use, primarily in Frederick County, but extends a short distance into Carroll County.

Lake Linganore lies in the Piedmont physiological province. The soils immediately surrounding the lake are Manor-Liganore-Montalto (USDA: Soil Conservation Service, 1960). The Montalto soils are deep, well drained, and fine textured while the Manor and Liganore are generally shallow to very shallow, excessively drained, immature, or skeletal. The outer watershed area is comprised of soils of the Duffield-Hagerstown Association. These soils are well drained soils developed from limestone. The area surrounding Lake Linganore, like the rest of Frederick County, has a humid, temperate climate with an average temperature of 50°F and an average precipitation range between 44 and 46 inches.

B. Water Supply Development

The County's Linganore/Spring Ridge water system is dependent on a 2.0 million gallons per day (MGD) water treatment plant, which started operation in 1993. The plant is equipped with two Trident Microfloc 420A package plants, each consisting of an upflow clarification chamber with absorption media and mixed media filter. The raw water intake structure which was constructed in 1999, is located in the lake with three levels of intake lines. The three intake lines are located at elevations of 294.62, 287.19 and 280.19 feet above mean sea level respectively. The valves on each line control the level of intake when the reservoir pool level drops during the periods of drought. Raw water flows by

gravity, through an 18-inch line by using control valves to withdraw from different reservoir levels to the plant's raw water basin. From the basin, water pumps by one of the two pumps to the head of the plant. Alum and chlorine are added prior to an in-line static mixers. If needed, carbon, lime and polymer can be added here to aid the treatment processes.

3.0 RESULTS OF SITE VISIT(S)

Water Supply Program personnel conducted a site survey of Frederick County water sources and other raw water facilities in order to accomplish the following tasks:

- To collect information regarding the locations of raw water sources and intakes by using Global Positioning System (GPS) equipment.
- To determine the general condition and structural integrity of intakes and other raw water facilities.
- To discuss source water issues and concerns with the County water system operators.
- To conduct a windshield survey of the watershed and to document potential problem areas. Additional tours of the watersheds were taken on follow-up visits.

A summary of site visits' findings and discussions is as follows:

Concerns and Site Observations

In addition to looking at the intake and immediate land along Lake Linganore, multiple visits were made to survey the watershed of Lake Linganore and its tributaries. The observed land use characteristics were compared with the Maryland Department of Planning's 2000 land use data and document. Meetings with plant operators and Lake Linganore Association officials were held to discuss concerns regarding the potential or known sources of contamination to the source water. The list below reflects plant operators, Lake Linganore Association members' concerns and MDE site observations:

- Frederick County's 30-inch sewer is located adjacent to Lake Linganore and runs parallel to the raw water intake line with less than 10 feet of separation distance.
- A sewer line above Lake Linganore has experienced some leakage in the past.
- Geese migration and activities around Lake Linganore.
- Sedimentation and siltation are the major concerns. A limited scope bathymetric study to determine the storage volume of the Lake at spillway elevation and loss of storage compared to the original design was completed by a consulting engineering firm in 2002. The report is attached in Appendix A.

- Lake Linganore Association members expressed concerns that under existing local regulations the watershed is not protected and is subject to development and other land use changes.
- Algea bloom during summer months and high turbidity during storms are the concerns expressed by the plant operators.

4.0 WATERSHED CHARACTERIZATION

Source Water Assessment Area Delineation Method (Surface Water)

An important aspect of the source water assessment process is to delineate the watershed area that contributes to the source of drinking water. A source water protection area is defined as the whole watershed area upstream from a water plant's intake (MDE, 1999). Delineation of the source water area was performed by using ESRI's Arc View Geographic Information Software (GIS), utilizing existing GIS data, and by collecting location data using a Global Positioning System (GPS). GPS point locations were taken at the water source intake and differentially corrected (for an accuracy of +/-2 meters) at MDE. Once the intake location was established, the contributing area was delineated based on existing Maryland Department of Natural Resources digital watershed data and Maryland State Highway Administration digital stream coverage. Digital USGS 7.5 topographical maps were also used to perform "heads up" digitizing, or editing, or watershed boundaries.

General Characteristics

The source water protection area for Lake Linganore intake encompasses approximately 81 square miles (52,000 acres) of mixed land use with predominantly cropland and forested land. The entire watershed is located in Frederick County with a small portion extending into Carroll County (Figure 3).

Land Use Characteristics

Based on the Maryland Department of Planning's 2000 land use data, the land use distribution in Lake Linganore Watershed is summarized as shown below:

Table 1. 2000 Land Use Data

Land Use	Total Area in Acres	Percent of Total Watershed
Low Density Residential	5816.9	11.2
Medium-High Residential	1930.1	3.7
Commercial/Industrial	416.2	0.8
Parks & Golf Courses	217.8	0.4
Cropland	25198.3	48.6
Pasture	3519.2	6.8
Forest	14314.4	27.6
Open Water	223.3	0.4
Wetlands	46.1	0.1

Table 1 continued

Concentrated Agriculture	142.8	0.3
Total	51825.1	100.0

Localized Characteristics

At the location of the County's intake, the topography of the surrounding area consists of steep slopes with only a gravel road leading to the intake's concrete valve box. The Lake Linganore development covers approximately 3,730 acres of land with an ultimate potential of 8,200 housing units surrounding the lake with swimming beaches and boat access ramps (Figure 1).

5.0 SIGNIFICANT SOURCES OF CONTAMINATION

Non-Point Concerns

According to 2000 Department of Planning land use data, 55.4% of the watershed is used for agricultural purposes (48.6% cropland, 6.8% pasture). Land used to grow crops can be a source of nutrients (from fertilizer), synthetic organic compounds (herbicides) and sediment load. If manure is used as a source of fertilizer for row crops then these fields in crop production can also release pathogens and organic carbon to the surrounding streams following rain events. Pastures used to graze livestock can be sources of nutrients and pathogenic protozoa, viruses and bacteria from animal waste. The predominate soils within the source protection area are from Manor-Glenelg and Manor-Linganore-Urbana series. The Manor soils, which dominate in these soil series, are fairly shallow and skeletal. Erosion throughout the region can create problems and careful farm management is important (New Market Region Plan, October 1993).

While less than 15% of the watershed is listed as residential, there are areas of concern based on their size and location:

Lake Linganore at Eaglehead, a Planned Unit Development (PUD) community, is located between I-70 and Gas House Pike and is approximately 3,730 acres. The PUD and surrounding area consist of a mixture of housing types including single family, villa and apartment units planned around Lake Linganore and five smaller lakes. In 1993, the population of Lake Linganore at Eaglehead was approximately 3,700 persons with an ultimate potential of 8,200 units and a population of 20,000-25,000 persons.

Another large Planned Unit Development is the Spring Ridge PUD located southwest of Lake Linganore, on both sides of I-70 and west of Quinn Road. In the area north of I-70, approximately half of this housing development is located within the watershed of Lake Linganore and includes a mixture of single family, townhouse and multi-family units. In 1993, the population of Spring Ridge was approximately 940 persons with an ultimate population expected to be

approximately 4,600 persons in over 1,500 housing units (Frederick County New Market Region Plan, October 1993).

Because of the close proximity of the above residential areas to Lake Linganore and high population density, pollution due to non-point runoff from this large housing development can be a major concern.

In addition to the above residential areas, there are two incorporated municipalities, the Towns of New Market, Mount Airy, two unincorporated communities, New London and Libertytown and there are several rural subdivisions and housing developments in the watershed with on-site septic systems.

Point Source Concerns

The only point source of pollution located in Lake Linganore watershed is the Libertytown Wastewater Treatment Plant. This facility, NPDES Permit MD0060577 is operated by Frederick County Division of Utilities and Solid Waste Management. Treated effluent is discharged into Town Branch, upper stream reaches of Linganore Creek. The Libertytown service area is approximately 0.5 square miles, encompassing the unincorporated community of Libertytown located at the intersection of M26 and 75. The community has a current population of 526. The Libertytown Wastewater Treatment Plant was built by the County in 1986 with a capacity of 50,000 GPD. It treats an average flow of 30,000 GPD. The projected population of Libertytown is expected to be 1,050 by the year 2010. The County is in the process of replacing this wastewater treatment plant with a new sewage pump station. The wastewater from the community of Libertytown will be pumped to the nearby sewer interceptor and treated in Frederick County's Wastewater Treatment Plant outside of the watershed.

Currently, the maximum permitted discharge is 50,000 gallons per day, with effluent limits of BOD₅ average monthly of 30 mg/l total suspended solid monthly average of 30 mg/l, and the concentration of fecal coliforms of 200 MPN per 100/milliter.

Transportation Related Concerns

Major roads in the Linganore Creek source water protection area include: Route 75 extending from the southern to northern boundaries of the watershed; Route 26 runs along the northern boundary for most of the watershed; and sections of Route 31 and Route 27 also located within the watershed boundary. There are also numerous secondary roads and residential access roads throughout the watershed. Concentration of residential access roads with heavy traffic within Lake Linganore at Eaglehead and lack of proper stormwater management practices in some areas of the development can expedite further siltation of Lake Linganore.

The following is a list of local roads in the watershed which are adjacent to and/or cross the tributaries and may be of concerns for spills: Boyers Mill Road (bridge over Lake Linganore), Gas House Pike (bridge over Linganore Creek), Old Annapolis Road, Woodville Road and Buffalo Road (See Figure 2).

Land Use Planning Concerns

A comparison between 1990 and 2000 Maryland DOP land use data shows changes in watershed land development. Land use percentages are shown below:

Table 2. Land Use Planning Concerns

Land Use	Percent of Watershed	Percent of Watershed	CHANGE:
	in 1990	in 2000	
Residential	6.2	14.9	+ 8.7
Industrial/Commercial	1.4	0.8	- 0.6
Urban Public Lands	0.6	0.4	- 0.2
Cropland	58.0	48.6	- 9.4
Pasture	7.6	6.8	- 0.8
Forest	25.4	27.6	+ 2.2
Open Water	0.3	0.4	+ 0.1
Wetlands	NA	0.1	0.1
Concentrated Agriculture	0.6	0.3	- 0.3

Note: Black = increase; Red = decrease

The most significant changes are the increase in residential land use and decrease of agricultural (cropland and pasture) land use over the past ten years in Lake Linganore watershed. This land use trend is also seen in the rest of Frederick County. A significant percentage of the land slated for new development on the south side of Lake Linganore, however, is currently forested and potential residential or commercial developments of large tracts of forested land in the watershed threatens the water quality in streams and Lake Linganore.

6.0 REVIEW OF WATER QUALITY DATA

Several sources of water quality data were reviewed for Lake Linganore source water assessment areas. These include MDE Water Supply Program's database for safe drinking water contaminants and monthly operating reports for Frederick County Water Treatment Plant, Frederick County Health Department, United States Geological Survey, MD Department of Natural Resources, and Lake Linganore Association and health department bacteriological data.

Water quality data for all three water sources will be compared with Maximum Contaminant Levels (MCLs) set by the U.S. Environmental Protection Agency to ensure safe drinking water. If the monitoring data is greater than 50% of a MCL for at least 10% of the time, a detailed susceptibility analysis will be performed for that contaminant and its potential sources.

Existing Plant Data

Frederick County is required to perform water quality tests on the drinking water it produces in order to ensure compliance with the EPA's Safe Drinking Water Act (SDWA) requirements. The County is also required to submit monthly operating reports to MDE's Water Supply Program, which includes daily testing of some raw water quality parameters such as turbidity (cloudiness of water), alkalinity, and pH. Other plant data included in the Monthly Operating Report (MOR) reflects the quality of treated (finished) water. All contaminants detects from plant data (finished) and the year 2000 raw water turbidity and pH for each plant are listed below.

Raw Water Turbidity and pH

Our review of Frederick County monthly operating reports from January 2000 to December 2000 indicates that the average monthly turbidity of the raw water fluctuates from 5.0 NTU to 31.7 NTU. The highest value recorded in 2000 was 113 NTU. The average pH of the raw water is from 7.3 to 8.1 and within the 6.5 – 8.5 range as recommended by secondary standard for drinking water. Below is a list of turbidity and pH values (monthly average, maximum and minimum) for Lake Linganore raw water during the year 2000.

Table 3. Linganore Plant Raw Water Turbidity and pH for 2000

	Average Monthly Value		Maximum / Month		Minimum / Month	
Date	Turb. NTU	PH	Turb. NTU	pH ·	Turb. NTU	рН
January	7.8	7.7	11	7.8	4.0	7.6
February	15.3	7.6	72	7.8	2.0	7.4
March	21.4	7.8	104	8.5	7.0	7.4
April	12.5	8.1	47	8.8	5.0	7.6
May	5.3	7.7	10	9.1	3.0	7.2
June	7.0	7.3	10	7.5	5.0	7.2
July	7.2	7.3	9	7.4	5.0	7.2
August	7.0	7.4	9	7.5	5.0	7.3
September	7.8	7.4	12	7.6	5.0	7.3
October	5.0	7.7	8	8.1	3.0	7.3
November	6.4	7.9	10	8.2	3.0	7.6
December	31.7	7.9	113	8.4	3.0	7.3
	Avg.	Avg. pH	Highest	Highest	Lowest	Lowest
	Turb/Year	year	Turb. In	pН	Turb.	pН
	NTU		Year 2000	Year 2000		
	11.2	7.65	113	9.1	2.0	7.2

Inorganic Compounds (IOCs)

Linganore plant regularly tests for the presence of nitrate and other inorganic compounds in finished drinking water. Below is a summary of testing results for IOCs detected in finished water. All data is expressed in milligrams per liter (mg/l). Fluorides added during the treatment process; therefore, levels are not reflective of raw water conditions. Twenty-three samples detected nitrate since 1993, none exceeded 50% of the MCL. The highest nitrate value reported (4.2 mg/l) was from the most recent sample collected in February of 2004.

Table 4. Inorganic Compounds (IOCs) from Lake Linganore

		able 4. Inorganic Compounds (100s) from Lar						
Contaminant	Sample Date	Result	Units	MCL				
ARSENIC	03/28/1995	0.001	mg/L	0.01				
BARIUM	03/28/1995	0.03	mg/L	2				
BARIUM	03/12/1997	0.03	mg/L	2				
BARIUM	05/28/1999	0.028	mg/L	2				
BARIUM	08/18/2000	0.025	mg/L	2				
BARIUM	05/16/2001	0.025	mg/L	2				
BARIUM	06/26/2002	0.0271	mg/L	2				
BARIUM	06/09/2003	0.0241	mg/L	2				
BARIUM	05/19/2004	0.0313	mg/L	2				
CHROMIUM	03/28/1995	0.003	mg/L	0.1				
CHROMIUM	05/19/2004	0.0021	mg/L	0.1				
FLUORIDE	03/28/1995	0.9	mg/L	4				
FLUORIDE	05/22/1995	0.97	mg/L	4				
FLUORIDE	05/29/1996	0.68	mg/L	4				
FLUORIDE	09/08/1996	0.97	mg/L	4				
FLUORIDE	03/12/1997	0.78	mg/L	4				
FLUORIDE	06/30/1997	0.97	mg/L	4				
FLUORIDE	05/04/1998	0.99	mg/L	4				
FLUORIDE	05/28/1999	0.9	mg/L	4				
FLUORIDE	08/18/2000	0.8	mg/L	4				
FLUORIDE	05/16/2001	0.76	mg/L	4				
FLUORIDE	08/07/2001	1.19	mg/L	4				
FLUORIDE	04/30/2002	1.18	mg/L	4				
FLUORIDE	06/26/2002	1.11	mg/L	4				
FLUORIDE	04/22/2003	0.72	mg/L	4				
FLUORIDE	06/09/2003	1.05	mg/L	4				
FLUORIDE	05/19/2004	1.02	mg/L	4				
NITRATE	03/02/1993	3.2	mg/L	10				
NITRATE	05/13/1993	3	mg/L	10				

Table 4 continued

NITRATE	08/30/1993	0.9	mg/L	10
NITRATE	10/21/1993	1.2	mg/L	10
NITRATE	03/28/1995	2.8	mg/L	10
NITRATE	05/22/1995	1.9	mg/L	10
NITRATE	05/31/1995	2	mg/L	10
NITRATE	11/15/1995	1.6	mg/L	10
NITRATE	02/27/1996	3.2	mg/L	10
NITRATE	09/08/1996	2.5	mg/L	10
NITRATE	01/28/1997	3.9	mg/L	10
NITRATE	06/30/1997	2	mg/L	10
NITRATE	01/07/1998	2.7	mg/L	10
NITRATE	05/04/1998	2.7	mg/L	10
NITRATE	02/10/1999	2.8	mg/L	10
NITRATE	02/09/2000	3.5	mg/L	10
NITRATE	01/24/2001	3.3	mg/L	10
NITRATE	08/07/2001	0.4	mg/L	10
NITRATE	01/30/2002	2	mg/L	10
NITRATE	04/30/2002	0.7	mg/L	10
NITRATE	02/28/2003	2.5	mg/L	10
NITRATE	04/22/2003	2.6	mg/L	10
NITRATE	02/05/2004	4.2	mg/L	10
NITRITE	05/22/1995	0.002	mg/L	1
NITRITE	05/31/1995	0.01	mg/L	1
NITRITE	09/08/1996	0.002	mg/L	1
NITRITE	04/30/2002	0.002	mg/L	1
SODIUM	03/12/1997	6.4	mg/L	*
SODIUM	06/30/1997	6.6	mg/L	
SODIUM	05/04/1998	6	mg/L	
SODIUM	08/18/2000	6.6	mg/L	
SODIUM	05/16/2001	6.9	mg/L	
SODIUM	08/07/2001	7.14	mg/L	
SODIUM	04/30/2002	8.72	mg/L	
SODIUM	06/26/2002	8.05	mg/L	
SODIUM	04/22/2003	8.15	mg/L	
SODIUM	06/09/2003	5.67	mg/L	
SODIUM	05/19/2004	7.4	mg/L	
SULFATE	03/15/1994	32	mg/L	250**
SULFATE	06/21/1994	16	mg/L	250**

Table 4 continued

SULFATE	09/26/1994	16	mg/L	250**
SULFATE	12/20/1994	20	mg/L	250**
SULFATE	03/06/1995	12	mg/L	250**
SULFATE	05/22/1995	12.58	mg/L	250**
SULFATE	05/31/1995	12.58	mg/L	250**
SULFATE	05/29/1996	11	mg/L	250**
SULFATE	09/08/1996	19.1	mg/L	250**
SULFATE	06/30/1997	13.1	mg/L	250**
SULFATE	05/04/1998	12.7	mg/L	250**
SULFATE	08/18/2000	12	mg/L	250**
SULFATE	05/16/2001	11.9	mg/L	250**
SULFATE	08/07/2001	16.8	mg/L	250**
SULFATE	04/30/2002	30.9	mg/L	250**
SULFATE	06/26/2002	22.2	mg/L	250**
SULFATE	06/09/2003	34.5	mg/L	250**
SULFATE	05/19/2004	28	mg/L	250**

^{*}EPA advisory for persons sensitive to salty taste between 30-60 ppm.

Radionuclides

No radionuclides were found in finished water at levels at or above 50% of established MCLs. Gross alpha emissions were reported as detectable and gross beta emissions are less than 10% of the screening level of 50 picocuries per liter.

Synthetic Organic Compounds (SOCs)

SOC samples are collected by Frederick County and MDE. Below is a summary of SOCs detected for years 1993-2004. All data is expressed in micrograms per liter (µg/l). Atrazine, a commonly used agricultural herbicide, was detected 19 times during these years, three times above 50% of the maximum contaminant level. A detailed discussion of the atrazine findings will be covered in the susceptibility analysis. No other compounds were detected at levels greater than 50% of the maximum contaminant levels.

Table 5. Synthetic Organic Compounds (SOCs)
Lake Linganore Creek Source

Edito Binguiore or	OUL SOULO			
Contaminant	Sample Date	Result	Units	MCL
2,4-D	05/11/04	0.16	μg/l	70
ATRAZINE	06/21/94	0.6	μg/l	3

^{**}secondary standard

~	• •		_		. •	1
. I . v	h	۵	•	cont	ากา	וממו
1 1	.,			COLL		ıcu

ATRAZINE	Table 5 continued			
ATRAZINE		09/26/94	0.1 μg/l	3
ATRAZINE	ATRAZINE	12/12/94	$0.1 \mu g/l$	3
ATRAZINE	ATRAZINE	05/15/95	0.73 μg/l	3
ATRAZINE ATRAZINE O5/06/98 0.49 µg/l 3 ATRAZINE O5/10/09 O7/13/98 O55 µg/l 3 ATRAZINE O5/10/00 O.12 µg/l 3 ATRAZINE O7/19/00 O.42 µg/l 3 ATRAZINE O7/11/01 O1/1 µg/l 3 ATRAZINE O6/26/02 O432 µg/l 3 ATRAZINE O6/26/02 O432 µg/l 3 ATRAZINE O6/09/03 O7/µg/l 3 ATRAZINE O6/09/03 O7/µg/l 3 ATRAZINE O6/09/03 O7/µg/l 3 ATRAZINE O6/09/03 O7/µg/l 3 ATRAZINE O7/16/03 O20 µg/l 3 ATRAZINE O7/18/04 O1 µg/l C0/19/99 O5 µg/l C0/19/99 O5 µg/l C0/10/04 O1 µg/l C0/10/05 O1/19/99 O5 µg/l C0/10/06 O1/19/99 O5 µg/l O1/10/06 O1/10/16 O1/10/06 O1/10/16 O1/1	ATRAZINE	05/21/96	2μg/l	
ATRAZINE ATRAZINE O5/06/98 0.49 µg/l 3 ATRAZINE O5/10/09 O7/13/98 O55 µg/l 3 ATRAZINE O5/10/00 O.12 µg/l 3 ATRAZINE O7/19/00 O.42 µg/l 3 ATRAZINE O7/11/01 O1/1 µg/l 3 ATRAZINE O6/26/02 O432 µg/l 3 ATRAZINE O6/26/02 O432 µg/l 3 ATRAZINE O6/09/03 O7/µg/l 3 ATRAZINE O6/09/03 O7/µg/l 3 ATRAZINE O6/09/03 O7/µg/l 3 ATRAZINE O6/09/03 O7/µg/l 3 ATRAZINE O7/16/03 O20 µg/l 3 ATRAZINE O7/18/04 O1 µg/l C0/19/99 O5 µg/l C0/19/99 O5 µg/l C0/10/04 O1 µg/l C0/10/05 O1/19/99 O5 µg/l C0/10/06 O1/19/99 O5 µg/l O1/10/06 O1/10/16 O1/10/06 O1/10/16 O1/1	ATRAZINE	06/20/96	$3.5 \mu g/l$	3
ATRAZINE	ATRAZINE	07/24/96	2.9μg/l	3
ATRAZINE 05/10/00 0.12 µg/l 3 ATRAZINE 07/19/00 0.42 µg/l 3 ATRAZINE 07/11/01 0.17 µg/l 3 ATRAZINE 06/26/02 0.432 µg/l 3 ATRAZINE 06/26/02 0.432 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 07/16/03 0.02 µg/l 3 ATRAZINE 05/19/04 0.2 µg/l 3 ATRAZINE 05/19/04 0.1 µg/l 3 ATRAZINE 07/28/04 0.1 µg/l 3 ATRAZINE 07/28/04 0.1 µg/l 3 DALAPON 04/19/99 0.65 µg/l 200 DALAPON 08/17/99 0.59 µg/l 200 DALAPON 05/31/00 0.1 µg/l 200 DALAPON 05/31/00 0.1 µg/l 200 DALAPON 05/31/00 0.8 µg/l 400 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8 µg/l 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 µg/l 400 DI(2-ETHYLHEXYL) PHTHALATE 05/26/95 1.78 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/99 0.5 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 0.23 µg/l 40 DI(2-ETHYLHEXYL) PHT	ATRAZINE	06/30/97	0.51 μg/l	3
ATRAZINE 05/10/00 0.12 µg/l 3 ATRAZINE 07/19/00 0.42 µg/l 3 ATRAZINE 07/11/01 0.17 µg/l 3 ATRAZINE 06/26/02 0.432 µg/l 3 ATRAZINE 06/26/02 0.432 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 07/16/03 0.02 µg/l 3 ATRAZINE 05/19/04 0.2 µg/l 3 ATRAZINE 05/19/04 0.1 µg/l 3 ATRAZINE 07/28/04 0.1 µg/l 3 ATRAZINE 07/28/04 0.1 µg/l 3 DALAPON 04/19/99 0.65 µg/l 200 DALAPON 08/17/99 0.59 µg/l 200 DALAPON 05/31/00 0.1 µg/l 200 DALAPON 05/31/00 0.1 µg/l 200 DALAPON 05/31/00 0.8 µg/l 400 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8 µg/l 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 µg/l 400 DI(2-ETHYLHEXYL) PHTHALATE 05/26/95 1.78 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/99 0.5 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 0.23 µg/l 40 DI(2-ETHYLHEXYL) PHT	ATRAZINE	05/06/98	$0.49 \mu g/l$	3
ATRAZINE 07/11/01 0.17 µg/l 3 ATRAZINE 06/26/02 0.432 µg/l 3 ATRAZINE 08/07/02 0.32 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 07/16/03 0.02 µg/l 3 ATRAZINE 05/19/04 0.2 µg/l 3 ATRAZINE 05/19/04 0.1 µg/l 3 DALAPON 04/19/99 0.65 µg/l 200 DALAPON 08/17/99 0.59 µg/l 200 DALAPON 05/31/00 0.1 µg/l 200 DALAPON 08/07/01 0.34 µg/l 200 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8 µg/l 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 µg/l 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.6 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.4 µg/l 40 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.4 µg/l 40 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.4 µg/l 40 DI(2-E	ATRAZINE	07/13/98	0.55 μg/l	3
ATRAZINE 07/11/01 0.17 µg/l 3 ATRAZINE 06/26/02 0.432 µg/l 3 ATRAZINE 08/07/02 0.32 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 06/09/03 0.7 µg/l 3 ATRAZINE 07/16/03 0.02 µg/l 3 ATRAZINE 05/19/04 0.2 µg/l 3 ATRAZINE 05/19/04 0.1 µg/l 3 DALAPON 04/19/99 0.65 µg/l 200 DALAPON 08/17/99 0.59 µg/l 200 DALAPON 05/31/00 0.1 µg/l 200 DALAPON 08/07/01 0.34 µg/l 200 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8 µg/l 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 µg/l 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.6 µg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.4 µg/l 40 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.4 µg/l 40 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.4 µg/l 40 DI(2-E	ATRAZINE	05/10/00	$0.12 \mu g/1$	3
ATRAZINE ATRAZINE D7/28/04 O1/28/04 O1/29/99 O.65 µg/1 O0/20/20 DALAPON D8/07/01 O.34 µg/1 O0/20-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) PHTHALATE D1(2-ETHYLHE	ATRAZINE	07/19/00	0.42 μg/l	3
ATRAZINE ATRAZINE D7/28/04 O1/28/04 O1/29/99 O.65 µg/1 O0/20/20 DALAPON D8/07/01 O.34 µg/1 O0/20-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) PHTHALATE D1(2-ETHYLHE	ATRAZINE	07/11/01	0.17μg/l	3
ATRAZINE ATRAZINE D7/28/04 O1/28/04 O1/29/99 O.65 µg/1 O0/20/20 DALAPON D8/07/01 O.34 µg/1 O0/20-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) PHTHALATE D1(2-ETHYLHE	ATRAZINE	06/26/02	0.432 μg/l	3
ATRAZINE ATRAZINE D7/28/04 O1/28/04 O1/29/99 O.65 µg/1 O0/20/20 DALAPON D8/07/01 O.34 µg/1 O0/20-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) PHTHALATE D1(2-ETHYLHE	ATRAZINE	08/07/02		3
ATRAZINE ATRAZINE D7/28/04 O1/28/04 O1/29/99 O.65 µg/1 O0/20/20 DALAPON D8/07/01 O.34 µg/1 O0/20-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) PHTHALATE D1(2-ETHYLHE	ATRAZINE	06/09/03		3
ATRAZINE ATRAZINE D7/28/04 0.1 µg/1 3 DALAPON 04/19/99 0.65 µg/1 200 DALAPON 08/17/99 0.59 µg/1 200 DALAPON 08/07/01 0.3 µg/1 200 DALAPON 08/07/01 0.3 µg/1 200 DALAPON 08/07/01 0.3 µg/1 200 DI(2-ETHYLHEXYL) ADIPATE D5/31/00 D(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) ADIPATE D1(2-ETHYLHEXYL) PHTHALATE D1(2-ETHYL	ATRAZINE	07/16/03	$0.02 \mu g/1$	
DALAPON 04/19/99 0.65 μg/l 200 DALAPON 08/17/99 0.59 μg/l 200 DALAPON 05/31/00 0.1 μg/l 200 DALAPON 08/07/01 0.34 μg/l 200 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8 μg/l 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 μg/l 400 DI(2-ETHYLHEXYL) ADIPATE 08/07/01 0.5 μg/l 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/06/98 </td <td>ATRAZINE</td> <td>05/19/04</td> <td></td> <td>3</td>	ATRAZINE	05/19/04		3
DALAPON 04/19/99 0.65 μg/1 200 DALAPON 08/17/99 0.59 μg/1 200 DALAPON 05/31/00 0.1 μg/1 200 DALAPON 08/07/01 0.34 μg/1 200 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8 μg/1 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 μg/1 400 DI(2-ETHYLHEXYL) ADIPATE 08/07/01 0.5 μg/1 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/06/98 </td <td>ATRAZINE</td> <td>07/28/04</td> <td>0.1 μg/l</td> <td>3</td>	ATRAZINE	07/28/04	0.1 μg/l	3
DALAPON 08/17/99 0.59 μg/1 200 DALAPON 05/31/00 0.1 μg/1 200 DALAPON 08/07/01 0.34 μg/1 200 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8 μg/1 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 μg/1 400 DI(2-ETHYLHEXYL) ADIPATE 08/07/01 0.5 μg/1 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 08/17/99 0.7 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE	DALAPON	04/19/99	$0.65 \mu g/l$	200
DALAPON 05/31/00 0.1 μg/1 200 DALAPON 08/07/01 0.34 μg/1 200 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8 μg/1 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 μg/1 400 DI(2-ETHYLHEXYL) ADIPATE 08/07/01 0.5 μg/1 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/06/98 0.16 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/1 60 DI(2-ETHYLHEXYL)	DALAPON	08/17/99	$0.59 \mu g/1$	200
DALAPON 08/07/01 0.34μg/1 200 DI(2-ETHYLHEXYL) ADIPATE 05/31/00 0.8μg/1 400 DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8μg/1 400 DI(2-ETHYLHEXYL) ADIPATE 08/07/01 0.5μg/1 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 08/17/99 0.7μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5μg/1 60 METOLACHLOR	DALAPON	05/31/00		200
DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 μg/l 400 DI(2-ETHYLHEXYL) ADIPATE 08/07/01 0.5 μg/l 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/17/99 0.7 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 METOLACHLOR 05/06/98 0.16 μg/l 4 METOLACHLOR 06/26/02 0.143 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02	DALAPON	08/07/01		200
DI(2-ETHYLHEXYL) ADIPATE 05/16/01 1.8 μg/l 400 DI(2-ETHYLHEXYL) ADIPATE 08/07/01 0.5 μg/l 400 DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/17/99 0.7 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 METOLACHLOR 05/06/98 0.16 μg/l 4 METOLACHLOR 06/26/02 0.143 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02	DI(2-ETHYLHEXYL) ADIPATE	05/31/00	$0.8 \mu g/1$	400
DI(2-ETHYLHEXYL) PHTHALATE 05/22/95 1.78 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/17/99 0.7 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 METHOXYCHLOR 05/06/98 0.16 μg/l 4 METOLACHLOR 06/21/94 0.8 μg/l 4 SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	DI(2-ETHYLHEXYL) ADIPATE	05/16/01		400
DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/17/99 0.7 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 METHOXYCHLOR 05/06/98 0.16 μg/l 4 METOLACHLOR 06/21/94 0.8 μg/l 4 SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	DI(2-ETHYLHEXYL) ADIPATE	08/07/01	$0.5 \mu g/l$	400
DI(2-ETHYLHEXYL) PHTHALATE 05/04/98 1.03 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/19/99 0.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/17/99 0.7 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/20/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 METHOXYCHLOR 05/06/98 0.16 μg/l 4 METOLACHLOR 06/21/94 0.8 μg/l 4 SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	DI(2-ETHYLHEXYL) PHTHALATE	05/22/95	1.78 μg/l	6
DI(2-ETHYLHEXYL) PHTHALATE 08/17/99 0.7 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 METHOXYCHLOR 05/06/98 0.16 μg/l 40 METOLACHLOR 06/21/94 0.8 μg/l 0 METOLACHLOR 06/26/02 0.143 μg/l 4 SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	DI(2-ETHYLHEXYL) PHTHALATE	05/04/98		6
DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 60 METHOXYCHLOR 05/06/98 0.16 μg/l 40 METOLACHLOR 06/21/94 0.8 μg/l METOLACHLOR 06/26/02 0.143 μg/l SIMAZINE 06/20/96 0.4 μg/l 40 SIMAZINE 07/19/00 0.23 μg/l 40 SIMAZINE 06/26/02 0.21 μg/l 40	DI(2-ETHYLHEXYL) PHTHALATE	04/19/99		6
DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.3 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 60 METHOXYCHLOR 05/06/98 0.16 μg/l 40 METOLACHLOR 06/21/94 0.8 μg/l METOLACHLOR 06/26/02 0.143 μg/l SIMAZINE 06/20/96 0.4 μg/l 40 SIMAZINE 07/19/00 0.23 μg/l 40 SIMAZINE 06/26/02 0.21 μg/l 40		08/17/99	0.7 μg/l	6
DI(2-ETHYLHEXYL) PHTHALATE 05/31/00 1.5 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 60 METHOXYCHLOR 05/06/98 0.16 μg/l 40 METOLACHLOR 06/21/94 0.8 μg/l METOLACHLOR 06/26/02 0.143 μg/l SIMAZINE 06/20/96 0.4 μg/l 40 SIMAZINE 07/19/00 0.23 μg/l 40 SIMAZINE 07/19/00 0.23 μg/l 40 SIMAZINE 06/26/02 0.21 μg/l	DI(2-ETHYLHEXYL) PHTHALATE	05/31/00	1.3 μg/l	6
DI(2-ETHYLHEXYL) PHTHALATE 08/07/01 1.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/30/02 1.1 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/1 60 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/1 60 METHOXYCHLOR 05/06/98 0.16 μg/1 40 METOLACHLOR 06/21/94 0.8 μg/1 METOLACHLOR 06/26/02 0.143 μg/1 SIMAZINE 06/20/96 0.4 μg/1 40 SIMAZINE 07/19/00 0.23 μg/1 40 SIMAZINE 06/26/02 0.21 μg/1 40 SIMAZINE	DI(2-ETHYLHEXYL) PHTHALATE	05/31/00	1.5 µg/l	6
DI(2-ETHYLHEXYL) PHTHALATE 04/22/03 0.6 μg/l 6 DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 METHOXYCHLOR 05/06/98 0.16 μg/l 40 METOLACHLOR 06/21/94 0.8 μg/l 0.8 μg/l METOLACHLOR 06/26/02 0.143 μg/l 0.4 μg/l 4 SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	DI(2-ETHYLHEXYL) PHTHALATE	08/07/01	1.6µg/l	6
DI(2-ETHYLHEXYL) PHTHALATE 05/11/04 0.5 μg/l 6 METHOXYCHLOR 05/06/98 0.16 μg/l 40 METOLACHLOR 06/21/94 0.8 μg/l METOLACHLOR 06/26/02 0.143 μg/l SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	DI(2-ETHYLHEXYL) PHTHALATE	04/30/02	1.1μg/l	6
METHOXYCHLOR 05/06/98 0.16 μg/l 40 METOLACHLOR 06/21/94 0.8 μg/l 0.16 μg/l 0.8 μg/l METOLACHLOR 06/26/02 0.143 μg/l 0.143 μg/l 0.143 μg/l 4 SIMAZINE 06/20/96 0.4 μg/l 4 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4		04/22/03	0.6μg/l	6
METOLACHLOR 06/21/94 0.8 μg/l METOLACHLOR 06/26/02 0.143 μg/l SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	DI(2-ETHYLHEXYL) PHTHALATE	05/11/04	0.5 μg/l	6
METOLACHLOR 06/26/02 0.143 μg/l SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	METHOXYCHLOR	05/06/98	0.16μg/l	40
SIMAZINE 06/20/96 0.4 μg/l 4 SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	METOLACHLOR	06/21/94	0.8μg/l	
SIMAZINE 07/19/00 0.23 μg/l 4 SIMAZINE 06/26/02 0.21 μg/l 4	METOLACHLOR	06/26/02	$0.143 \mu g/l$	
SIMAZINE 06/26/02 0.21 μg/1 4	SIMAZINE	06/20/96	0.4μg/l	4
	SIMAZINE	07/19/00	$0.23 \mu g/1$	4
SIMAZINE $08/07/02 \ 0.14 \mu g/l \ 4$	SIMAZINE	06/26/02	0.21 μg/l	4
	SIMAZINE	08/07/02	0.14μg/l	4

Volatile Organic Compounds (VOCs)/Disinfection Byproduct

No volatile organic compounds other than disinfection by-products were detected in the finished water leaving Linganore Water Treatment Plant. Compliance with the disinfection by-product standards is determined by levels in the distribution system. Levels of disinfection by products in the distribution exceed 50% of the recently established MCLs for total trihalomethanes (80 μ g/l) and haloacetic acids (60 μ g/l). In 2004, levels of haloacetic acids in the distribution system were in excess of the maximum contaminant levels.

Frederick County has been monitoring disinfection byproducts (DBPs) in the distribution system to monitor compliance with Stage 1 Disinfectants and Disinfection Byproduct Rule (DBPR). The DBPs are total trihalomethanes (TTHMs) and haloacetic acids (HAA). The sum of the concentration of four compounds chloroform, bromochloromethane, dibromochloromethane, and bromoform comprise TTHM and the sum of five compounds mono-, di-, and trichloroacetic acids, and mono- and di-bromoacetic acids comprise HAAs. The THM and HAA values for annual and quarterly concentrations are presented in Table 6 and Table 7.

Table 6. Annual Concentrations of Disinfection Byproducts in Lake Linganore Distribution System (all sample locations¹) All values

reported in micrograms per liter (µg/l).

		THM			HAA	
Year	Average	Max	Min	Average	Max	Min
2002	60.48	93.9	29.1	42.31	55.1	30.3
2003	58.01	141.7	19.0	59.58	177.0	16.2
2004	46.54	84.2		67.79	119.8	37.3
Total	53.80	141.7		59.87	177.0	16.2

¹Based on samples from four locations: 6540 Twin Lake Drive, 6114 Samuel Road, 7007 Clubhouse Circle, 6135 Field Crest Drive.

Table 7. Quarterly Average Concentrations of Disinfection Byproducts in the Distribution System. All values reported in

micrograms per liter (ug/l).

	THM			HAA		
Quarter	Average	Max	Min	Average	Max	Min
1	34.78	80.6	-	50.06	119.8	16.2
2	49.82	84.2	24.8	65.94	177.0	22.3
3	82.93	141.7	41.2	66.77	120.0	33.9
4	58.11	85.8	35.1	43.60	51.0	35.2
Total	53.80	141.7		59.87	177.0	16.2

In addition, total organic carbon (TOC) is used as a surrogate for precursors DBPPs. TOC has been monitored in the raw and treated water. The TOC values

by quarter are shown in Table 8 below. The highest TOC values are found during the third quarter where there is a greater likelihood of more biological activity (algal growth) within the reservoir. It is also during this quarter that the highest average concentration of HAA was measured over the last three years.

Table 8. Quarterly Average Concentrations of Source and Treated Total Organic Carbon and Percent Removed (2001 through 2004) at the Lake Linganore Water Treatment Plant

0	1	TOC (n	•	Treated TOC (mg/l) Average Max Min		Percent Removal		al	
Quarter	Averag	ge Max	MIII	Average	Max	Min	TOC Average	e Max	Min
Jan – Mar	2.47	4.25	0.91	1.61	2.70	0.57	34%	48%	7%
Apr – Jun	3.21	5.17	1.45	2.12	3.00	1.10	33%	52%	18%
Jul – Sep	3.94	7.29	2.63	2.41	3.87	1.64	36%	72%	17%
Oct - Dec	3.33	5.43	1.37	2.20	3.54	0.85	33%	47%	21%
All Data	3.28	7.29	0.91	2.11	3.87	0.57	34%	72%	7%

The Disinfection Byproducts Rule (DBPR) requires that water systems serving 10,000 or more persons must comply with the rule's provisions beginning December 2001. The rule establishes MCLs for the most common and well-studied halogenated DBPs: total trihalomethane (TTHMs) and five of the nine haloacetic acids (HAAs) as well as bromate and chlorite. TTHM is defined as the sum of chloroform, bromoform, bromodichloromethane, and dibromochloromethane; HAA is defined as the sum of mono-, di-, and trichloroaceticaeids, and mono- and dibromacetic acids. The MCLs for the disinfection byproducts are shown in Table 9:

Total 9. MCLs for the Stage 1 DBPR

Total Trihalomethanes (TTHMs)	80 μg/l
Haloacetic Acids (HAAs)	60 μg/l
Bromate	60 μg/l
Chlorite	1.0 μg/l

In addition to MCLs, the DBPR requires the use of treatment techniques to reduce DBP precursors and to minimize the formation of unknown DBPs. It requires that a specific percentage of influent total organic carbon (TOC) be removed during treatment. The treatment technique uses TOC as a surrogate for natural organic matter (NOM), the precursor material for DBPs. A TOC concentration of greater than 2.0 mg/l in a system's raw water is the trigger for implementation of the treatment technique. Required removal of TOC by enhanced coagulation for plants using conventional treatment is shown in Table 10.

Table 10. Total Organic Carbon Removal Requirements

Source Water TOC	Source Water Alkalinity (mg/l as CaCo3)			
(mg/l)	0-60	>120		
>2.0 – 4.0	35%	25%	15%	
>4.0 – 8.0	45%	35%	25%	
>8.0	50%	40%	30%	

Review of the TOC data collected by Frederick County from 2002 through 2004 indicates that the treatment process usually removes the required percentage of TOC from the Linganore Creek raw water.

Protozoa and Fecal Coliform

Lake Linganore Association operates several bathing beaches around the lake in accordance with the County Health Department permit. Review and analysis of the data from the County Health Department, Lake Linganore Association, and data from Frederick County Department of Public Works since 1991 reveals that fecal coliform counts exceeded the 200 MPN per 100 ml on several occasions. A total of 267 sample results from various sites at Lake Linganore were analyzed to determine the values of the minimum, maximum, and geometric mean of the existing data. The range of the values are: minimum from 1.5 to 20, maximum from 1,100 to 240,000 and geometric mean from 46.8 to 988.6.

MDE, with cooperation of Frederick County water treatment operators, completed a two-year bacteriological monitoring program. The raw water samples were collected bi-weekly and tested for fecal coliform and E.Coli. A summary of monthly average, maximum and minimum concentrations of Fecal Coliform from March 2001 to December 2002 is shown in Table 11. Results from the intake sampling show a high level of variability but with most values below the state water quality standard of 200 mpn for fecal coliform that was in effect at the time of the sampling.

Table 11. Monthly Summary of Lake Linganore Intake Results for Fecal Coliform

Month	Fecal Coliform (MPN)				
	Average	Maximum	Minimum		
Mar-01	9.0	30	2		
Apr-01	196.0	800	2		
May-01	11.6	50	2		
Jun-01					
Aug-01	6.8	17	2		
Sep-01	753.0	3,000	2		
Oct-01	12.2	30	2		
Nov-01	50.8	170	7		
Dec-01	120.0	180	50		

Jan-02	4.6	13	2
Feb-02	2.5	4	2
Mar-02	227.0	900	2
Apr-02	7.3	23	2
May-02	38.6	80	2
Jun-02	71.0	170	2
Jul-02	3.2	8	2
Nov-02	377.2	1,100	26
Dec-02	1,678.0	5,000	11
Total	160.1	5,000	2

Table 11 continued

MDE completed a three-year study to determine the occurrence and concentrations of Cryptosporidium oocysts in selected intakes along the Potomac River and in smaller water supply watershed tributaries. Cryptosporidium is a water-borne parasite that has been implicated in water-borne disease outbreaks in drinking water. Linganore Creek was selected as one of the sample sites in MDE's study. As part of this study, samples were collected for baseflow and stormflow from Linganore Creek at Gas House Pike upstream of the reservoir. All four baseflow sample results show negative for Cryptosporidium at Linganore Creek sampling site. Stormflow samples were taken during pre-storm, peak and post storm events. From the total of 12 samples, eight samples tested positive and four tested negative for Cryptosporidium. The data shown in Tables 12-15 are the sample results during each stormflow event. The data clearly shows the effect of increased runoff on the levels of Cryptosporidium observed.

Table 12. Storm Event #1 Cryptosporidium Results

Sampling Sequence	Pre-Storm	Peak-Storm	Post-Storm
Sample date	09/25/2001	09/25/2001	09/26/2001
Oocysts/Liter	Negative	29	3
Total Number	Negative	327	37
Viable/Infectious	NA	V	V

NA = Not Viable; All samples were 3-gallons

Table 13. Storm Event #2 Cryptosporidium Results

Sampling Sequence	Pre-Storm	Peak-Storm	Post-Storm
Sample date	01/24/2002	01/24/2002	01/25/2002
Oocysts/Liter	Negative	21	2
Total Number	Negative	241	24
Viable/Infectious	NA	V	V

NA = Not Viable; All samples were 3-gallons

Table 14. Storm Event #3 Cryptosporidium Results

Sampling Sequence	Pre-Storm	Peak-Storm	Post-Storm
Sample date	03/18/2002	03/18/2002	03/19/2002
Oocysts/Liter	Negative	24	2
Total Number	Negative	271	23
Viable/Infectious	NA	V	V

NA = Not Viable; All samples were 3-gallons

Table 15. Storm Event #4 Cryptosporidium Results

Sampling Sequence	Pre-Storm	Peak-Storm	Post-Storm
Sample date	06/13/2002	06/13/2002	06/14/2002
Oocysts/Liter	Negative	15	1
Total Number	Negative	173	12
Viable/Infectious	NA	V	V

NA = Not Viable; All samples were 3-gallons

7.0 SUSCEPTIBILITY ANALYSIS

Each class of contaminants with significant levels reported in Chapter 6.0 were further analyzed based on the potential they have of contaminating the Lake Linganore and Frederick County water intake. This analysis identified suspected sources, evaluated the natural conditions that may decrease or increase the likelihood of contaminant reaching the intake, and evaluate the impacts that future changes within the watershed may have on the susceptibility of the water intake.

Turbidity and Sediment

The average raw water turbidity in the Lake Linganore Treatment Plant during the year 2000 was approximately 11.2 NTU; the highest monthly average turbidity of 31.7 NTU was recorded during the month of December, 2000. High levels of turbidity in Lake Linganore can result from storm events (rainfall) and snowmelt. The sediment loads into Lake Linganore are severe because of the steps slopes and erodible soils concurrent with the residential development surrounding some of the lake and the high percentage of agricultural land in the watershed. A limited scope bathymetric survey was performed by a consulting engineering firm to estimate the amount of sedimentation that has occurred in Lake Linganore since it was constructed. The study also estimated the remaining reservoir capacity and the feasibility and cost options for restoring the lake capacity. The report concluded that the lake has lost approximately 13% of its capacity in the 27 years between the dam construction year of 1972 and 1999. A copy of Siltation and Capacity Report prepared by Whitman, Requardt & Associates, LLP, December 2002, is included in Appendix A.

Future land use changes in the Lake Linganore watershed could increase the turbidity contamination. Most of the watershed is privately owned and

development of forested land will increase the amount of exposed surfaces that can lead to increased erosion. Lake Linganore is susceptible to elevated turbidity.

Inorganic Compounds

All inorganic compounds except phosphorous are discussed in this section. All the inorganic compounds (IOCs) that have been detected are below the maximum contaminant level in the finished water from Lake Linganore Water Treatment Plant. Nitrate was the most common IOC detected but no results exceeded 50% of the Maximum Contaminant Level (MCL). Nitrates can enter the water supply via ground water and surface runoff. Fertilizer losses, leachate from septic tanks and animal waste are considered sources of nitrates. If the amount of livestock, fertilizer usage and conversion of forested lands to residential development using on-site disposal increases, then nitrate concentration will increase in the future. Nitrate is not considered a threat to the Lake Linganore water supply at the present time.

Very low levels of other inorganic compounds have been detected in the finished water leaving Lake Linganore Water Treatment Plant (Table 4). None have been greater than 50% of the respective MCL. Lake Linganore is not susceptible to IOCs.

Total Phosphorus

Since phosphorus is the limiting nutrient for algae growth in Lake Linganore, phosphorus reduction is needed to reduce eutrophication stresses on the reservoir system. A reduction in algae levels is expected to lead to lower levels of reactive organic carbon and consequently lower levels of disinfection byproducts in the treated water. Phosphorus is the eleventh most abundant mineral in the earth's crust; fresh water phosphorus exists in either particulate phase or a dissolved phase. Particulate matter includes living and dead plankton, precipitate of phosphorus, phosphorus absorbed to particulates and amorphous phosphorus. The dissolved phase includes inorganic phosphorus (generally in the soluble orthophosphate form), organic phosphorus excreted by organisms, and macromolecular colloidal phosphorus. External sources of phosphorus include agricultural and urban runoff, wastewater effluents and runoff from forested land. A comparison between phosphorus loading (in terms of pounds per acre per year) from the discharge of the Libertytown Wastewater Plant and agricultural land in the watershed revealed that the contribution from the wastewater plant is rather insignificant compared to agricultural activities in the watershed (Chesapeake Model DNR). Farming practices would have to be adopted to either reduce fertilizer applications or to reduce runoff from fertilized land to reduce phosphorus loading. The contribution of phosphorus from land in residential development has not been quantified.

According to the Total Maximum Daily Loads' (TMDLs) report prepared by MDE for Lake Linganore (December 2002) the major water quality problems of Lake Linganore were associated with high phosphorus and high sediment loads.

The water quality goal of these TMDLs is to reduce long-term phosphorus and sediment loads to acceptable levels consistent with the physical characteristics of Lake Linganore. This reduced loading rate is predicted to resolve excess algal problems and maintain a dissolved oxygen concentration above the State's water quality standard. The TMDL for phosphorus was determined using an empirical method known as the Vollenweider Relationship. Because the reduction of sediments is a component of controlling external phosphorus loads, a sediment loading rate consistent with narrative water quality criteria is predicted to be achieved.

The average annual TMDL for phosphorus is 5,288 lbs/yr. There is one point source in the Lake Linganore basin. Consequently, the allocation is partitioned between nonpoint sources, the point source and the margin of safety. For sediments, the TMDL is established to achieve a loading rate consistent with the uses of the lake, as a result of the proposed control of phosphorus. This loading rate is estimated to result in preserving about 48% - 79% of the lake's design volume over a period of 40 years.

Synthetic Organic Compounds (SOCs)

There are several SOC detects at the Lake Linganore plant, but all results are less than 50% of MCL, with the exception of three samples of atrazine (Table 5). The MCL for atrazineis 3 micrograms per liter (µg/l). The highest concentrations were from 1996, with all results in the past 5 years less than 0.7 µg/l. Atrazine has been documented to enter streams and rivers in Maryland following springtime herbicide application. Atrazine is water soluble, and residues on soil, vegetation or other surfaces can be easily carried by runoff into streams. The highest concentrations in Lake Linganore intake were measured in late spring and early summer. A review of Maryland Pesticide Statistics for the past decade indicates that the usage of atrazine in Frederick County is declining. This reduction is due to both a declining number of acres in row crop production and a reduction in the allowed application rates. Therefore given the changing land use it is likely that atrazine concentration will continue to decrease in the future. Lake Linganore is therefore not susceptible to SOCs.

Disinfection Byproducts

Trihalomethanes (THMs) and haloacetic acids (HAAs) both exceeded 50% of the MCL and in 2004 HAAs were in excess of maximum contaminant levels in the distribution system. Organic carbon compounds in the raw water contributed by the elevated HAAs by reacting with chlorine in the treatment plant and distribution system.

The amount and type of organic matter in Lake Linganore is due to the contribution of organic carbon from the watershed and the production of algae from nutrients delivered by the watershed to the lake. Watershed sources of organic carbon include decying vegetation (leaves), airborne deposition, soil erosion and animal wastes.

Due to the nature of the watershed, the biological status of the reservoir (inreservoir process "algae blooms" and decomposition of aquatic plants) and occasionally high sample concentrations of HAA and THM, the Lake Linganore water system is susceptible to disinfection byproducts.

Microbiological Contaminants

The consistent presence of fecal coliform bacteria in Lake Linganore indicates its susceptibility to pathogenic microorganisms. The fecal coliform data from different sources, summarized in Section 6.0 Review of Water Quality Data, shows that counts periodically exceeded the previous state standard of 200 MPN/l00 ml. Three sampling locations: Ben's Branch, Linganore Creek and Nightingale Beach test results from June 1992-September 2001show the highest geometric mean value of 602, 988 and 355 MPN/l00 ml respectively.

Giardia and cryptosporidium are fairly common in surface water and associated with human and animal waste, including livestock, horses, pets, birds and various wildlife species such as deer, raccoons, opossums, rabbits, rats and squirrels. Young calves infected with cryptosporidium are significant sources of very high levels of cryptosporidium, particularly if they have direct access to streams. The management of livestock waste, including limiting the access of livestock from flowing streams would reduce the susceptibility of this water supply to pathogenic protozoas. Like most all surface water supplies, the water intake is susceptible to contamination by giardia, cryptosporidium and other pathogens. Sampling data indicates that highest fecal and cryptosporidium levels are associated with the peak periods of stormwater runoff (see Tables 12, 13, 14, 15). Sampling locations indicate that high levels are present prior to entering the reservoir, thus indicating that watershed sources, especially agricultural lands, are likely to be the most significant.

8.0 RECOMMENDATIONS FOR SOURCE WATER PROTECTION PLAN

This report is compiled based on the existing and available data from several sources. It provides general information as a first step towards establishing and implementing source water protection plans for Frederick County's Lake Linganore source. Additional data may be needed to further understand the areas delineated for specific source protection goals. The following is a list of recommendations regarding watershed management for each source.

- Frederick County should become an active member of Lake Linganore source water protection committee group, interested in development and implementation of strategies to protect Lake Linganore as a drinking water source.
- Develop a formal or informal agreement to engage officials from different jurisdictions on a continuing basis.
- Encourage broad stakeholder participation, including home owners, farmers, developers and existing environmental groups.
- Establish clear and achievable goals, objectives and milestones to ensure the highest quality raw water. Some examples are listed below.
 - ✓ Implement recommendations of Lake Linganore Siltation and Capacity report of December 9, 2002 by Whitman, Requardt & Associates.
 - ✓ Develop a predictive model to relate the tributary nutrient loadings to the lake eutrophication, water quality parameters and algae dynamics.
 - ✓ Develop baseline information on pathogen contamination in main feeder streams and at different lake locations. Continue monitoring for fecal coliform and e.Coli.
 - ✓ Ensure that all farms with livestock have developed and are implementing best management practices for their animals. Addressing bare ground areas and areas where livestock (and particularly their young) have direct access to free flowing streams should be the highest priority for reducing the risk from pathogenic protozoans.
 - ✓ Keep track of water quality compliance violations and refer them to
 MDF
 - Monitor the major tributaries for TOC and disinfection byproduct formation potential seasonally. Tributary monitoring may help pinpoint watersheds that are major precursor contributors.
 - ✓ The County should explore the possibility of acquiring land and
 conservation easements in sensitive watershed areas and along the
 feeder streams. Loan grants for the purchase of land or easements for
 the purpose of protecting water are available from MDE and through
 the Maryland Agricultural Preservation Funds.
 - ✓ Frederick County should periodically conduct its own detailed field survey of the watershed to ensure there are no new potential sources of contaminants.
 - ✓ In cooperation with Frederick City, conduct ongoing monitoring for algae and/or indicators of algae blooms, such as chlorophyla levels in Lake Linganore.
 - ✓ Monitor for phosphorus in major tributaries and in reservoir.

REFERENCES

- City of Frederick Comprehensive Plan, Adopted August 17, 1995.
- County, City and Lake Linganore and Regional Water System Agreement, December 2000.
- Frederick County Comprehensive Plan, 1997, A Countywide Plan for Frederick County, Maryland.
- MDE, Water Supply Program, 1999, Maryland's Source Water Assessment Plan (SWAP).
- MDE, Total Maximum Daily Loads for Phosporus and Sediment of Lake Linganore, Frederick County, MD, December 2002.
- Maryland Pesticide Statistics for 1997, 1994, 1991-1988 and 1985, Maryland Department of Agriculture.
- Middle Potomac River Basin Environmental Assessment of Stream Conditions, December 1998, Maryland Department of Natural Resources (MDNR).
- Monocacy River Scenic River Study and Management Plan, 1990.
- New Market Region Plan, Adopted October 1993, Frederick County, Maryland.
- Piney Alloway Creek's Targeted Watershed Project Summary Report, 1990-1997, August 1999, MDNR.
- U.S. Army Corps of Engineers, Baltimore District, 1980, Linganore Dam, Phase 1 Inspection Report.
- Water Quality Trends in Big Pipe Creek During the Double Pipe Creek Rural Clean Water Program, John L. McCoy and Robert M. Summers, Proceedings of National RCWP Symposium 1992.
- Whitman, Requardt & Associates, 1979, Lake Linganore Water Quality Study.
- Whitman, Requardt & Associates, 2002 Lake Linganore Siltation & Capacity Report.

OTHER SOURCES OF DATA

- EPA's Guidance Manual for Source Water Assessments
- Maryland Department of Planning 2000, Frederick County Land-use Maps
- MDE NPDES Permits
- MDE Waste Management Sites Database
- MDE Water Appropriation and Use Permits
- MDE Water Supply Inspection Reports.
- MDE Water Supply Oracle Database.
- Frederick County Water Treatment Plant Monthly Operating Reports (MORs) and Self-Monitoring Reports

FIGURES



